



Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
 40 J. Miranda Avenue, Naga City

PRODUCTION DEPARTMENT
WATER QUALITY DIVISION
 DOH ACCREDITATION NO. 05-007-2022-LW-1

RESULT OF BACTERIOLOGICAL POTABILITY TESTING OF WATER SAMPLE

Name: Baao Water District
Address: La Medalla, Baao, Cam. Sur
OR # 248787
Date: 7-Dec-20
Amount : 5,400.00

Type of Examination : FCT
Sample Lab. No. B20-12-120 to 128
Collected by: E. L. Marifosque
Date/Time Released: _____
Signature: _____
Name: _____

REMARKS: _____

Laboratory No.	Sample/Location	Sampling Point/ Source	Date & Time Collected	Total Coliforms (MPN/100 ml)	Fecal Coliforms (MPN/100 ml)	HPC Test (CFU/ml)	Remarks
B20-12-120	Aiza Jane N. Parima San Antonio, Pob. Nabua, C. S.	FAUCET/ Deep Well	12/14/2020 7:35 AM	<1.1	<1.1	1	PASSED
B20-12-121	Salcedo Victorino San Francisco, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 7:46 AM	<1.1	<1.1	0	PASSED
B20-12-122	Nancy Badong San Nicolas, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 8:00 AM	<1.1	<1.1	3	PASSED
B20-12-123	Monico Benosa, Sr. De Rosario, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 8:50 AM	<1.1	<1.1	0	PASSED
B20-12-124	Gerald Boreta Sta. Cruz, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 9:04 AM	<1.1	<1.1	22	PASSED
B20-12-125	Olga Beldad La Medalla, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 9:21 AM	<1.1	<1.1	2	PASSED
B20-12-126	Wendelina Britanico Buluan, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 9:37 AM	<1.1	<1.1	6	PASSED
B20-12-127	Constancio Bitao San Isidro, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 9:50 AM	<1.1	<1.1	0	PASSED
B20-12-128	Emilia Melie De Loria Sta. Teresita, Baao, C. S.	FAUCET/ Deep Well	12/14/2020 10:03 AM	<1.1	<1.1	1	PASSED

MPN - Most Probable Number of Coliform

CFU - Colony Forming Units

HPC - Heterotrophic Plate Count

PNSDW - Philippine National Standards for Drinking Water

Total Coliform Test (TCT)

Fecal Coliform Test (FCT)

Colony Forming Units/ml

Less than 1.1 or 0

Less than 1.1 or 0

<500

Analyzed by:

ZANDRA S. GUTIERREZ, RMT
 Medical Technologist II
 OIC, WQAS & LTAS

Attested by:

ROQUE S. FRANCISCO
 DMA, WREMP/OIC-WQD
 OIC, Production Department

Checked by:

SUZETTE ANGELI C. BABAGAY, MD
 Pathologist



Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
40 J. Miranda Avenue, Naga City

CERTIFICATION

This is to certify that water sample / samples submitted by Baao Water District
with address at La Medalla, Baao, Cam. Sur as per Laboratory No.: B20-12-120 to 128
is / are within the Bacteriological Standard for drinking water at the time of examination.

Issued on this day of 18th DECEMBER 2020.


ROQUE S. FRANCISCO
DMA, WPEMD / OIC-WQD
OIC, Production Department
