



Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
 40 J. Miranda Avenue, Naga City

PRODUCTION DEPARTMENT
WATER QUALITY DIVISION
 DOH ACCREDITATION NO. 05-001 - 16-LW-1

RESULT OF BACTERIOLOGICAL POTABILITY TESTING OF WATER SAMPLE

Name: BAAO WATER DISTRICT
 Address: La Medalla, Baao, Cam. Sur
 OR #: 242514
 Date: 28-Jan-20
 Amount: 5,400.00

Type of Examination : FCT
 Sample Lab. No. : B20-02-270 to 278
 Collected by: E. MARIFOSQUE
 Date/Time Released: _____
 Signature: _____
 Name: _____

REMARKS: _____

Laboratory No.	Sample/Location	Sampling Point/ Source	Date & Time Collected	Total Coliforms (MPN/100 ml)	Fecal Coliforms (MPN/100 ml)	HPC Test (CFU/ml)	Remarks
B20-02-270	Marilo Morando San Antonio, Nabua, C. S.	FAUCET/ Deep Well	2/11/2020 7:18 AM	<1.1	<1.1	0	PASSED
B20-02-271	Hereberto Berya Sta. Teresita, Baao, C. S.	FAUCET/ Deep Well	2/11/2020 8:16 AM	<1.1	<1.1	0	PASSED
B20-02-272	Elvie Pacto Lanipga, Bula, C. S.	FAUCET/ Deep Well	2/11/2020 8:34 AM	<1.1	<1.1	1	PASSED
B20-02-273	Erwin Agravate Pawili, Bula, C. S.	FAUCET/ Deep Well	2/11/2020 9:15 AM	<1.1	<1.1	0	PASSED
B20-02-274	Jovie Borita Banasi, Bula, C. S.	FAUCET/ Deep Well	2/11/2020 9:29 AM	<1.1	<1.1	0	PASSED
B20-02-275	Dolores Agvilad Fabrica, Bula, C. S.	FAUCET/ Deep Well	2/11/2020 9:55 AM	<1.1	<1.1	6	PASSED
B20-02-276	Nestor Cervas Agdangan, Baao, C. S.	FAUCET/ Deep Well	2/11/2020 10:10 AM	<1.1	<1.1	0	PASSED
B20-02-277	Arcelie De Guia San Isidro, Baao, C. S.	FAUCET/ Deep Well	2/11/2020 10:28 AM	<1.1	<1.1	0	PASSED
B20-02-278	Lendi Badilla Buluang, Baao, C. S.	FAUCET/ Deep Well	2/11/2020 11:00 AM	<1.1	<1.1	0	PASSED

MPN - Most Probable Number of Coliform

CFU - Colony Forming Units

HPC - Heterotrophic Plate Count

PNSDW - Philippine National Standards for Drinking Water

Total Coliform Test (TCT)

Less than 1.1 or 0

Fecal Coliform Test (FCT)

Less than 1.1 or 0

Colony Forming Units/ml

<500

Analyzed by:

ZANDRA S. GUTIERREZ, RMT
 Medical Technologist II
 OIC, WQAS & LTAS

Checked by:

LAARNIE N. CALE-SUBIA, MD, FPSP
 Pathologist

Attested by:

ROQUE S. FRANCISCO
 DMA, WPEMD/OIC-WQD
 OIC, Production Department