



Republic of the Philippines  
**METROPOLITAN NAGA WATER DISTRICT**  
 40 J. Miranda Avenue, Naga City

**PRODUCTION DEPARTMENT**  
**WATER QUALITY DIVISION**  
 DOH ACCREDITATION NO. 05-001 - 16-LW-1

**RESULT OF BACTERIOLOGICAL POTABILITY TESTING OF WATER SAMPLE**

Name: BAAO WATER DISTRICT  
 Address: La Medalla, Baao, Cam. Sur  
 OR # 241703  
 Date: 7-Jan-20  
 Amount: 5,400.00

Type of Examination : FCT  
 Sample Lab. No. B20-01-230 to 238  
 Collected by: E. MARIKOSQUE  
 Date/Time Released: \_\_\_\_\_  
 Signature: \_\_\_\_\_  
 Name: \_\_\_\_\_

REMARKS: \_\_\_\_\_

Laboratory No.	Sample/Location	Sampling Point/ Source	Date & Time Collected	Total Coliforms (MPN/100 ml)	Fecal Coliforms (MPN/100 ml)	HPC Test (CFU/ml)	Remarks
B20-01-230	Romel Badiola San Juan, Baao, C. S.	FAUCET/ Deep Well	1/14/2020 8:10 AM	<1.1	<1.1	36	<b>PASSED</b>
B20-01-231	Mary Jane Biliver Sagrada, Baao, C. S.	FAUCET/ Deep Well	1/14/2020 8:30 AM	<1.1	<1.1	1	<b>PASSED</b>
B20-01-232	Marites Serno Baras, Nabua, C. S.	FAUCET/ Deep Well	1/14/2020 8:45 AM	<1.1	<1.1	45	<b>PASSED</b>
B20-01-233	Evangeline Gallarte Bagumbayan, Baao, C. S.	FAUCET/ Deep Well	1/14/2020 9:00 AM	<1.1	<1.1	0	<b>PASSED</b>
B20-01-234	Lolita Befete San Vicente, Baao, C. S.	FAUCET/ Deep Well	1/14/2020 9:20 AM	<1.1	<1.1	0	<b>PASSED</b>
B20-01-235	Salvacion Elem. School Salvacion, Baao, C. S.	FAUCET/ Deep Well	1/14/2020 9:35 AM	<1.1	<1.1	2	<b>PASSED</b>
B20-01-236	Luis Ballesteros San Ramon, Baao, C. S.	FAUCET/ Deep Well	1/14/2020 9:50 AM	<1.1	<1.1	1	<b>PASSED</b>
B20-01-237	Romana Bomanglag San Jose, Baao, C. S.	FAUCET/ Deep Well	1/14/2020 10:07 AM	<1.1	<1.1	2	<b>PASSED</b>
B20-01-238	Philippine National Police Nabua Cam. Sur	FAUCET/ Deep Well	1/14/2020 10:35 AM	<1.1	<1.1	0	<b>PASSED</b>

MPN - Most Probable Number of Coliform

CFU - Colony Forming Units

HPC - Heterotrophic Plate Count

PNSDW - Philippine National Standards for Drinking Water

Total Coliform Test (TCT)

Less than 1.1 or 0

Fecal Coliform Test (FCT)

Less than 1.1 or 0

Colony Forming Units/ml

<500

Analyzed by:

**ZANDRA S. GUTIERREZ, RMT**  
 Medical Technologist II  
 OIC, WQAS & LTAS

Checked by:

**LAARNIE N. CALE-SUBIA, MD, FPSP**  
 Pathologist

Attested by:

**ROQUE S. FRANCISCO**  
 DMA, WPEMD/OIC-WQD  
 OIC, Production Department