



Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
 40 J. Miranda Avenue, Naga City

PRODUCTION DEPARTMENT
WATER QUALITY DIVISION
DOH ACCREDITATION NO. 05-007-2022-LW-1

TEST REPORT OF MICROBIOLOGICAL ANALYSIS

Name: Baao Water District
Address: La Medalla, Baao, Cam. Sur
OR # 249295
Date: 4-Jan-21
Amount : 5,400.00

Type of Examination : FCT
Sample Lab. No. B21-01-327, 328, 330 to 335
Collected by: Marifosque, Ernie L.
Date/Time Released:
Signature:
Name:

REMARKS:

Laboratory No.	Sample/Location	Sampling	Date & Time	RESULTS OF ANALYSIS			Remarks
				Total Coliforms (MPN/100 ml)	Thermotolerant / Fecal Coliforms (MPN/100 ml)	HPC Test (CFU/ml)	
B21-01-327	Leticia Moite Pawili, Bula, Cam. Sur	FAUCET/ Deep Well	1/25/2021 8:46 AM	<1.1	<1.1	2	PASSED
B21-01-328	Ronald Nacario Fabrica, Bula, Cam. Sur	FAUCET/ Deep Well	1/25/2021 9:03 AM	<1.1	<1.1	1	PASSED
B21-01-330	Wilmar Emor Agdangan, Baao, Cam. Sur	FAUCET/ Deep Well	1/25/2021 9:49 AM	<1.1	<1.1	8	PASSED
B21-01-331	Heriberto Beria Sta. Teresita, Baao, Cam. Sur	FAUCET/ Deep Well	1/25/2021 10:04 AM	<1.1	<1.1	3	PASSED
B21-01-332	Maribel Brillo San Isidro, Baao, Cam. Sur	FAUCET/ Deep Well	1/25/2021 10:42 AM	<1.1	<1.1	0	PASSED
B21-01-333	Almera Britaneo Buluang, Baao, Cam. Sur	FAUCET/ Deep Well	1/25/2021 10:54 AM	<1.1	<1.1	22	PASSED
B21-01-334	Allan Francis Abendante La Medalla, Baao, Cam. Sur	FAUCET/ Deep Well	1/25/2021 11:00 AM	<1.1	<1.1	1	PASSED
B21-01-335	Aiza Jane Parima San Antonio, Nabua, Cam. Sur	FAUCET/ Deep Well	1/25/2021 11:20 AM	<1.1	<1.1	9	PASSED

Legend : Test Method used : MULTIPLE TUBE FERMENTATION TECHNIQUE (MTFT), SMEW 20th Edition.

Note : Results of examination are specifically related to samples as received.

MPN - Most Probable Number of Coliform

CFU - Colony Forming Units

HPC - Heterotrophic Plate Count

PNSDW - Philippine National Standards for Drinking Water 2017

Total Coliform Test (TCT)

Less than 1.1 or 0

Fecal Coliform Test (FCT)

Less than 1.1 or 0

Colony Forming Units/ml

<500

Analyzed by:

ZANDRA S. GUTIERREZ, RMT
 Medical Technologist II
 OIC, WQAS & LTAS

Checked by:

SUZETTE ANGELI C. BABAGAY, MD
 Pathologist

Attested by:

ROQUE S. FRANCISCO
 DMA, WPEMD/OIC-WQD
 OIC, Production Department




Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
40 J. Miranda Avenue, Naga City

CERTIFICATION

This is to certify that water sample / samples submitted by Bao Water District
with address at La Medalla, Bao, Cam. Sur as per Laboratory No. B21-01-327, 328, 330 to 335
is / are within the Bacteriological Standard for drinking water at the time of examination.

Issued on this day of 29th JANUARY 2021.


ROQUE S. FRANCISCO
DMA, WPEMD / OIC-WQD
OIC, Production Department

