



Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
 40 J. Miranda Avenue, Naga City

PRODUCTION DEPARTMENT
WATER QUALITY DIVISION
 DOH ACCREDITATION NO. 05-001 - 16-LW-1

RESULT OF BACTERIOLOGICAL POTABILITY TESTING OF WATER SAMPLE

Name: BAAO WATER DISTRICT
Address: La Medalla, Baao, Cam. Sur
OR # 243739
Date: 4-Mar-20
Amount : 5,400.00

Type of Examination : FCT
Sample Lab. No. B20-03-173 to 181
Collected by: E. MARIFOSQUE
Date/Time Released: _____
Signature: _____
Name: _____

REMARKS: _____

Laboratory No.	Sample/Location	Sampling Point/ Source	Date & Time Collected	Total Coliforms (MPN/100 ml)	Fecal Coliforms (MPN/100 ml)	HPC Test (CFU/ml)	Remarks
B20-03-173	Marilo Morando San Antonio, Nabua, C. S.	FAUCET/ Deep Well	3/9/2020 7:30 AM	<1.1	<1.1	0	PASSED
B20-03-174	Salcedo Victorino San Francisco, Baao, C. S.	FAUCET/ Deep Well	3/9/2020 7:54 AM	<1.1	<1.1	1	PASSED
B20-03-175	Francisco Badilla San Nicolas, Baao, C. S.	FAUCET/ Deep Well	3/9/2020 8:12 AM	<1.1	<1.1	1	PASSED
B20-03-176	Celedonio Abian Jr. San Jose, Baao, C. S.	FAUCET/ Deep Well	3/9/2020 8:25 AM	<1.1	<1.1	0	PASSED
B20-03-177	Carlos Badiola San Roque, Baao, C. S.	FAUCET/ Deep Well	3/9/2020 8:37 AM	<1.1	<1.1	1	PASSED
B20-03-178	Monico Benosa Sr. Del Rosario, Baao, C. S.	FAUCET/ Deep Well	3/9/2020 8:43 AM	<1.1	<1.1	0	PASSED
B20-03-179	Noel Badong Sta. Cruz, Baao, C. S.	FAUCET/ Deep Well	3/9/2020	<1.1	<1.1	10	PASSED
B20-03-180	Cathrina Mea Fajardo San Vicente, Baao, C. S.	FAUCET/ Deep Well	3/9/2020 9:10 AM	<1.1	<1.1	62	PASSED
B20-03-181	Noemi Buena Sab Juan, Baao, C. S.	FAUCET/ Deep Well	3/9/2020 9:33 AM	<1.1	<1.1	0	PASSED

MPN - Most Probable Number of Coliform

CFU - Colony Forming Units

HPC - Heterotrophic Plate Count

PNSDW - Philippine National Standards for Drinking Water

Total Coliform Test (TCT)

Less than 1.1 or 0

Fecal Coliform Test (FCT)

Less than 1.1 or 0

Colony Forming Units/ml

<500

Analyzed by:

ZANDRA S. GUTIERREZ, RMT
 Medical Technologist II
 OIC, WQAS & LTAS

Checked by:

LAARNIE N. CALE-SUBIA, MD, FPSP
 Pathologist

Attested by:

ROQUE S. FRANCISCO
 DMA, WPREMD/OIC-WQD
 OIC, Production Department