



Republic of the Philippines  
**METROPOLITAN NAGA WATER DISTRICT**  
 40 J. Miranda Avenue, Naga City

**PRODUCTION DEPARTMENT**  
**WATER QUALITY DIVISION**  
 DOH ACCREDITATION NO. 05-001 - 16-LW-1

**RESULT OF BACTERIOLOGICAL POTABILITY TESTING OF WATER SAMPLE**

**Name:** BAAO WATER DISTRICT  
**Address:** Baao, Cam. Sur  
**OR #** 244411  
**Date:** 5-May-20  
**Amount :** 5,400.00

**Type of Examination :** FCT  
**Sample Lab. No.** B20-05-68 to 76  
**Collected by:** E. MARIFOSQUE  
**Date/Time Released:** \_\_\_\_\_  
**Signature:** \_\_\_\_\_  
**Name:** \_\_\_\_\_

**REMARKS:** \_\_\_\_\_

Laboratory No.	Sample/Location	Sampling Point/ Source	Date & Time Collected	Total Coliforms (MPN/100 ml)	Fecal Coliforms (MPN/100 ml)	HPC Test (CFU/ml)	Remarks
B20-05-68	Marilo Marando San Antonio, Nabua, C. S.	FAUCET/ Deep Well	5/11/2020 7:00 AM	<1.1	<1.1	1	<b>PASSED</b>
B20-05-69	Epefaniao Bumanlag San Francisco, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 7:20 AM	<1.1	<1.1	1	<b>PASSED</b>
B20-05-70	Nernane Bayos San Roque, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 7:36 AM	<1.1	<1.1	0	<b>PASSED</b>
B20-05-71	Rusuera Brebante Del Rosario, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 7:50 AM	<1.1	<1.1	25	<b>PASSED</b>
B20-05-72	Norel Buena Sta. Cruz, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 8:00 AM	<1.1	<1.1	16	<b>PASSED</b>
B20-05-73	Romir Aglugub San Vicente, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 8:15 AM	<1.1	<1.1	2	<b>PASSED</b>
B20-05-74	Teresita San Buenaventura San Juan, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 8:27 AM	<1.1	<1.1	10	<b>PASSED</b>
B20-05-75	Fe Arispe San Ramon, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 9:00 AM	<1.1	<1.1	3	<b>PASSED</b>
B20-05-76	Felino Bayrante San Nicolas, Baao, C. S.	FAUCET/ Deep Well	5/11/2020 9:11 AM	<1.1	<1.1	1	<b>PASSED</b>

MPN - Most Probable Number of Coliform  
 CFU - Colony Forming Units  
 HPC - Heterotrophic Plate Count  
 PNSDW - Philippine National Standards for Drinking Water

Total Coliform Test (TCT) Less than 1.1 or 0  
 Fecal Coliform Test (FCT) Less than 1.1 or 0  
 Colony Forming Units/ml <500

Analyzed by:

**ZANDRA S. GUTIERREZ, RMT**  
 Medical Technologist II  
 OIC, WQAS & LTAS

Checked by:

**LAARNIE N. CALE-SUBIA, MD, FPSP**  
 Pathologist

Attested by:

**ROQUE S. FRANCISCO**  
 DMA, WPEMD/OIC-WQD  
 OIC, Production Department