



Republic of the Philippines
METROPOLITAN NAGA WATER DISTRICT
 40 J. Miranda Avenue, Naga City

PRODUCTION DEPARTMENT
WATER QUALITY DIVISION
 DOH ACCREDITATION NO. 05-007-2022-LW-1

RESULT OF BACTERIOLOGICAL POTABILITY TESTING OF WATER SAMPLE

Name: Baao Water District
 Address: La Medalla Baao, Cam. Sur
 OR #: 247591
 Date: 6-Oct-20
 Amount: 5,400.00

Type of Examination : FCT
 Sample Lab. No. : B20-10-168 to 174, 176
 Collected by: E. Marifosque
 Date/Time Released: _____
 Signature: _____
 Name: _____

REMARKS: _____

Laboratory No.	Sample/Location	Sampling Point/ Source	Date & Time Collected	Total Coliforms (MPN/100 ml)	Fecal Coliforms (MPN/100 ml)	HPC Test (CFU/ml)	Remarks
B20-10-168	Marelyn Peñaberde San Antonio, Pb. Nabua, CS	FAUCET/ Deep Well	10/19/2020 7:03 AM	<1.1	<1.1	0	PASSED
B20-10-169	Allan Billoñes San Francisco, Baao, CS	FAUCET/ Deep Well	10/19/2020 7:14 AM	<1.1	<1.1	32	PASSED
B20-10-170	Rogelio Pinigat San Roque, Baao, CS	FAUCET/ Deep Well	10/19/2020 7:35 AM	<1.1	<1.1	10	PASSED
B20-10-171	Gima Mamanarig Del Rosario, Baao, CS	FAUCET/ Deep Well	10/19/2020 7:53 AM	<1.1	<1.1	0	PASSED
B20-10-172	Dr. Robosa Hospital Sta. Cruz, Baao, CS	FAUCET/ Deep Well	10/19/2020 8:06 AM	<1.1	<1.1	21	PASSED
B20-10-173	Guancho Fajardo San Vicente, Baao, CS	FAUCET/ Deep Well	10/19/2020 8:19 AM	<1.1	<1.1	2	PASSED
B20-10-174	Narciso Villareal San Juan, Baao, CS	FAUCET/ Deep Well	10/19/2020 8:43 AM	<1.1	<1.1	2	PASSED
B20-10-176	Jeddah Regalado Baras, Nabua, CS	FAUCET/ Deep Well	10/19/2020 9:08 AM	<1.1	<1.1	26	PASSED

MPN - Most Probable Number of Coliform
 CFU - Colony Forming Units
 HPC - Heterotrophic Plate Count
 PNSDW - Philippine National Standards for Drinking Water

Total Coliform Test (TCT) Less than 1.1 or 0
 Fecal Coliform Test (FCT) Less than 1.1 or 0
 Colony Forming Units/ml <500

Analyzed by:

ZANDRA S. GUTIERREZ, RMT
 Medical Technologist II
 OIC, WQAS & LTAS

Checked by:

SUZETTE ANGELI C. BABAGAY, MD
 Pathologist

Attested by:

ROQUE S. FRANCISCO
 DMA, WPEMD/OIC-WQD
 OIC, Production Department