

SUITE 807, UNION SQUARE CONDOMINIUM 15<sup>TH</sup> AVENUE, CUBAO, QUEZON CITY  
TEL/FAX: 8911-3062/8912-6537/8291-6749 Email: platinumlaboratory@gmail.com

## TEST REPORT

**Sample Lab. No.** : 20-1500  
**Submitted By** : Baao Water District  
**Address** : Baao, Camarines Sur  
**Contact Number** : (02)8741-6556  
**Sample Source** : Deepwell  
**Sample Location** : Agdangan PH

**Date/Time of** : 20-Dec-2020  
**Collection** : 1:55 PM  
**Receipt** : 21-Dec-2020  
**Examination** : Jan. 4-8, 2021  
**Test Report #** : PC-2021-0036

WATER QUALITY				
PHYSICAL ANALYSIS				
Parameters	Results	PNSDW Limit	MDL	Methodology
Turbidity (NTU)	: 0.95	5		2130 B. Nephelometric Method
Apparent Color (Color Units)	: 5	10		2120 B. Visual Comparison
CHEMICAL ANALYSIS				
pH*	: 7.07	6.5 - 8.5		4500-H+ B. Electrometric
Total Dissolved Solids (mg/L)*	: 461	600		2540 C. Gravimetric dried at 180°C
Sulfate (mg/L)*	: 12.6	250		4500-SO <sub>4</sub> <sup>2-</sup> E. Turbidimetric
Nitrate (mg/L)	: 6.1	50		4500-NO <sub>3</sub> <sup>-</sup> D Electrode Method
Chloride (mg/L)	: 30	250		4500-Cl- B. Argentometric
METAL ANALYSIS (mg/L)				
Iron (mg/L, total)	: 0.02	1.00		3111 B. Direct Air-Acetylene
Manganese (mg/L, total)	: 0.03	0.40		3111 B. Direct Air-Acetylene
Arsenic (mg/L)	: <MDL	0.01	0.004	3113 B. Electrothermal AAS
Cadmium (mg/L)	: <MDL	0.003	0.0005	3113 B. Electrothermal AAS
Lead (mg/L)	: <MDL	0.01	0.002	3113 B. Electrothermal AAS

**NOTES:** \* ISO/IEC 17025:2005 Accredited Parameters.

**MDL** - Method Detection Level

**PNSDW** - Philippine National Standards for Drinking Water


*Data italicized are provided by the customer.*

The result apply only to the sample tested by PRLI and shall not be interpreted as approval, disapproval, rejection or endorsement of product from which the sample was obtained.


Result(s) of the examination is/are specifically related to sample(s) as received.

**REFERENCES:** American Public Health Association, American Water Works Association, and Water Environment Federation. 2012 Standard Methods for the Examination of Water and Waste Water. 22nd Edition., American Public Health Assoc., Washington D.C.  
Dept. of Health, Philippine National Standards for Drinking Water 2017


Analyzed by:

  
**Lorraine Mae S. Asaytuno**  
PRC No. 0013916  
Date: January 11, 2021

Certified by:

  
**Harlene Joy L. Cruz**  
PRC No. 0009512  
Date: January 11, 2021

Noted by:

  
**Louvelyn A. Bagarra**  
PRC No. 0025350  
Date: January 11, 2021

End of Report

**THIS REPORT IS NOT VALID WITHOUT DRY SEAL**

**THIS REPORT CANNOT BE DUPLICATED OR REPRODUCED EXCEPT IN FULL AND SHALL NOT BE USED FOR ADVERTISEMENT OR LITIGATION WITHOUT THE WRITTEN PERMISSION FROM PRLI**