

SUITE 807, UNION SQUARE CONDOMINIUM 15TH AVENUE, CUBAO, QUEZON CITY
TEL/FAX: 8911-3062/8912-6537/8291-6749 Email: platinumlaboratory@gmail.com

TEST REPORT

Sample Lab. No. : 20-1498
Submitted By : Baao Water District
Address : Baao, Camarines Sur
Contact Number : (02)8741-6556
Sample Source : Deepwell
Sample Location : San Juan PH

Date/Time of : 20-Dec-2020
Collection : 1:15 PM
Receipt : 21-Dec-2020
Examination : Jan. 4-8, 2021
Test Report # : PC-2021-0034

WATER QUALITY				
PHYSICAL ANALYSIS				
Parameters	Results	PNSDW Limit	MDL	Methodology
Turbidity (NTU)	0.98	5		2130 B. Nephelometric Method
Apparent Color (Color Units)	5	10		2120 B. Visual Comparison
CHEMICAL ANALYSIS				
pH*	6.53	6.5 - 8.5		4500-H+ B. Electrometric
Total Dissolved Solids (mg/L)*	254	600		2540 C. Gravimetric dried at 180°C
Sulfate (mg/L)*	3.0	250		4500-SO ₄ ²⁻ E. Turbidimetric
Nitrate (mg/L)	5.2	50		4500-NO ₃ ⁻ D Electrode Method
Chloride (mg/L)	8	250		4500-Cl- B. Argentometric
METAL ANALYSIS (mg/L)				
Iron (mg/L, total)	0.02	1.00		3111 B. Direct Air-Acetylene
Manganese (mg/L, total)	<MDL	0.40	0.009	3111 B. Direct Air-Acetylene
Arsenic (mg/L)	<MDL	0.01	0.004	3113 B. Electrothermal AAS
Cadmium (mg/L)	<MDL	0.003	0.0005	3113 B. Electrothermal AAS
Lead (mg/L)	<MDL	0.01	0.002	3113 B. Electrothermal AAS

NOTES: * ISO/IEC 17025:2005 Accredited Parameters.

MDL - Method Detection Level

PNSDW - Philippine National Standards for Drinking Water


Data italicized are provided by the customer.

The result apply only to the sample tested by PRLI and shall not be interpreted as approval, disapproval, rejection or endorsement of product from which the sample was obtained.


Result(s) of the examination is/are specifically related to sample(s) as received.

REFERENCES: American Public Health Association, American Water Works Association, and Water Environment Federation. 2012 Standard Methods for the Examination of Water and Waste Water. 22nd Edition., American Public Health Assoc., Washington D.C.
Dept. of Health, Philippine National Standards for Drinking Water 2017


Analyzed by:


Lorraine Mae S. Asaytuno
PRC No. 0013916
Date: January 11, 2021

Certified by:


Harlene Joy L. Cruz
PRC No. 0009512
Date: January 11, 2021

Noted by:


Louvelyn A. Bagarra
PRC No. 0025350
Date: January 11, 2021

End of Report

THIS REPORT IS NOT VALID WITHOUT DRY SEAL

THIS REPORT CANNOT BE DUPLICATED OR REPRODUCED EXCEPT IN FULL AND SHALL NOT BE USED FOR ADVERTISEMENT OR LITIGATION WITHOUT THE WRITTEN PERMISSION FROM PRLI